

Declaration of Conformity



Reference No.: WT09124473-U-D-L
Applicant: Fangyuan Electric Apparatus Co., Ltd
Address: Jiage Street, Anqiu, Weifang, Shandong Province, China
Manufacturer: Fangyuan Electric Apparatus Co., Ltd
Address: Jiage Street, Anqiu, Weifang, Shandong Province, China
Product: Uninterruptible Power System
Model No.: MD-6015-W
Technical Data: Input: 230VAC, 50Hz, 8A
Output: 65VAC, 975VA

Test Standards: EN 62040-1-1: 2003

The above product has been tested by us with the listed standards and found in compliance with the European Directive LVD 2006/95/EC. It is possible to use CE marking to demonstrate the compliance with this LVD Directive.

Uninterruptible power systems (UPS) -- Part 1-1: General and safety requirements for UPS used in operator access areas

The referred test report shows that the product complies with standards recognized as giving presumption of compliance with the essential requirements in the above listed EU Directive. Other relevant Directives have to be observed.

After preparation of the necessary technical documentation as well as the conformity declaration, the CE marking as shown below can be affixed on the equipment.



Manager
Date: January 20, 2010



The statement is based on a single evaluation of the sample of above mentioned products. It does not imply an assessment of the whole production.

WALTEK SERVICES CO., LTD.

Add: 12B, West Tower, Aid Building, No.5003 Binhe Rd., Futian District, Shenzhen, China.
Tel: 86-755-83551033 Fax: 86-755-83552400
Http://www.waltek.com.cn E-mail: info@waltek.com.cn

Declaration of Conformity



Reference No.: WT09124472-U-E-E
Applicant: Fangyuan Electric Apparatus Co., Ltd.
Address: Jiage Street, Anqiu, Weifang, Shandong Province, China
Manufacturer: Fangyuan Electric Apparatus Co., Ltd.
Address: Jiage Street, Anqiu, Weifang, Shandong Province, China
Product: Uninterruptible Power System
Model No.: MD-6015-W
Technical Data: Input: AC 230V, 50Hz
Output: AC 65V

Test Standards:

EN 62040-2:2006
EN 61000-3-2:2006
EN 61000-3-3:2008

The above product has been tested by us with the listed standards and found in compliance with the European Electromagnetic Compatibility Directive 2004/108/EC. It is possible to use CE marking to demonstrate the compliance with this EMC Directive.

EN 62040-2: Uninterruptible power systems (UPS) -Part 2: Electromagnetic compatibility (EMC) requirements
EN 61000-3-2: Electromagnetic Compatibility (EMC) Part 3-2: Limits for harmonic current emissions(Equipment input current up to and including 16A per phase.)
EN 61000-3-3: Electromagnetic Compatibility (EMC) Part 3-3: Limitation of voltage supply systems for equipment with rated current $\leq 16A$

The referred test report shows that the product complies with standards recognized as giving presumption of compliance with the essential requirements in the above listed EU Directive.
Other relevant Directives have to be observed.

After preparation of the necessary technical documentation as well as the conformity declaration, the CE marking as shown below can be affixed on the equipment.



Thales zheng
Manager
Date: January 21, 2010



The statement is based on a single evaluation of the sample of above mentioned products. It does not imply an assessment of the whole production.

WALTEK SERVICES CO., LTD.

Add: 12B, West Tower, Aidi Building, No.5003 Binhe Rd., Futian District, Shenzhen, China.
Tel: 86-755-83551033 Fax: 86-755-83552400
Http://www.waltek.com.cn E-mail: info@waltek.com.cn